LPG Supplemental Information

MGO 34.105 (22)(a):

A Work Permit is required for the installation or modification of all Liquefied Petroleum Gas (LPG) retail cylinder exchanges and for LPG containers of one hundred (100) gallons, or aggregate, water capacity or more.

LP-Gas (IFC 61) MFD work permit MGO 34.02(2)(h)10:

- 1. Retail Cylinder Exchanges of more than 100 gallons, or aggregate \$250 each
- 2. LPG Individual containers less than 2,000 gallons \$250 each
- 3. LPG Individual containers aggregate less than 4,000 gallons \$250 each

Exception: LPG tanks for temporary use at construction sites do not require a permit.

With the submittal includes copies of the site plan, tank information, technical data and copy of Department of Safety and Professional Services approval (if applicable).

When DSPS does plan review:

Liquid Petroleum Gas tank installation - 2000 gallon and larger, or 4000 gallon aggregate, per SPS 340.42; Compressed Natural Gas tank installation - any size installations, per SPS 340.61; Liquid Natural Gas tank installation - 2000 gallon and larger, per Comm 40.51; Gaseous Hydrogen Facilities - any size installations, per SPS 340.71; Liquefied Hydrogen Facilities - 2000 gallon and larger, or 4000 gallon aggregate, per SPS 340.81; Installation of Anhydrous Ammonia systems per SPS 343.10.

DSPS also does plan review regardless of tank size when dispensing is involved.

https://dsps.wi.gov/Pages/Programs/PlanReview/Gas.aspx