CITY OF MADISON, WISCONSIN

AN ORDINANCE		PRESENTED REFERRED	August 6, 2019 BC, FC, CC & LA Board
•	on 29.22 of the Madison General include exits from basements and		
	used for sleeping.		
		DK A	H
Drafted by:	Kate Smith	DIVI	1 1
Date:	July 29, 2019		
SPONSORS:			
DRAFTER'S ANALYSIS: Section 29.22 is created to incentivize the installation of home fire sprinklers and allow builders and homeowners greater flexibility in the design and construction of one- and two-family dwellings. The Uniform Dwelling Code ("UDC") currently requires basements and ground floors used for sleeping must be provided with at least two exits. Builders and homeowners may choose to install fire sprinklers throughout their home in lieu of a second exit from sleeping areas in basements. Home fire sprinklers are proven to save lives, property and the environment. The current UDC requirements recognize home fire sprinklers as an alternative to a second exit from habitable floor levels above the second floor. The proposal is not more or less restrictive than the UDC. It offers the builder and homeowner an alternative to a second exit. The option allows greater flexibility in the code to address site conditions that are unfavorable for a second exit of egress window.			
Note: This amendment will become effective upon approval by DSPS.			

The Common Council of the City of Madison do hereby ordain as follows:			
Section 29.22 entitled "Exits From Basements and Ground Floors Used for Sleeping" of the Madison General Ordinances is created to read as follows:			
"29.22 EXITS FROM BASEMENTS AND GROUND FLOORS USED FOR SLEEPING. (1) In this section:			
(2)	"Basement" refers to that portion its entire floor below grade. "Fire sprinklers" means an auton automatically when its heat-activated en allowing water to discharge over a specific floor means the first floor absence of a ground floor or basement "Ground floor" means that leve with a sloping or multilevel grade and with the following is in addition to the require a. Wis. Adm. § SPS 321.03(5)(b) i. A second exit from a beginning or multilevel grade and with the following is in addition to the require a.	pmatic fire suppression lement is heated to its cliffed area. I level above any grour means the lowest flood of a dwelling, below the which has a portion of its rements of Wis. Admin. I shall be amended to asement or ground flood	nd floor or basement or, in the or level in the dwelling. he first floor, located on a site is floor line at grade. Code ch. 321:
			Approved as to form:

EDITOR'S NOTE: Wis. Adm. § SPS 321.03(5)(b)1. reads as follows:

- "(b) Basements and ground floors used for sleeping.1. Basements and ground floors used for sleeping shall be provided with at least 2 exits."